



महाराष्ट्र शासन

सत्यमेवजयते

विद्युत निरीक्षकांचे कार्यालय,
राम-लक्ष्मण संकुल, ब्लॉक डी, 'शिवनेरी सदर पहीला माळा'
कॉटन मार्केट रोड, विलास नगर, अमरावती

ईमेल : ciamaravati-nrg-mh@gov.in

दुरध्वनी क्र.०७२१ - २५७३७८६

जा.क्र./वि.नि./निरीक्षण/ ९०९ /२०२४

दिनांक :- १८.०९.२०२४

To,

The Principle

School of scholars, CUBS

At- Malu Layout , Kaloti Nagar Benoda Amravati

Tq. Dist- Amravati

संदर्भ:- १. आपले निरीक्षण मागणी पत्र क्र- ३६ दिनांक- २७/५/२०२४.

२.या कार्यालयाचे निरीक्षण दिनांक ०३.०६.२०२४.

३.या कार्यालयाचे त्रुटी पत्र क्र.४०१/०३.०६.२०२४ .

४. आपल्या संचमांडणीचा मे.अश्विन इलेक्ट्रिकल नागपुर यांनी प्रमाणितकेलेलाचाचणी अहवाल व त्रुटी पुर्तता क्र.१५२९/दिनांक २८.०५.२०२४.

उपरोक्त पत्रान्वये आपण विनंती केल्यानुसार प्राचार्य स्कूल ऑफ स्कॉलर्स स्कब्स, मालु ले-आऊट, कलोती नगर बेनोडा, अमरावती येथील विद्युत संचमांडणीचे निरीक्षण या कार्यालयामार्फत दिनांक ०३.०६.२०२४ रोजी करण्यात आले असून ,सदर विद्युत संचमांडणी ,विज कायदा २००३ व केंद्रीय विद्युत प्राधिकरण विनियम २०२३ च्या नियमानुसार खालील अटीच्या अधिन राहून सद्यस्थितीत सर्व साधारणपणे सुरक्षित असल्याबाबत प्रमाणित करण्यात येत आहे.

- 1) A person having certificate of competency for electrical work issued by appropriate government shall be appointed by user department for maintenance of electrical installation,addition/alteration of load /wiring.
- 2) wiring diagrams/singal line diagrams of all electrical installations along with load details shall be displayed at electrical panel room.
- 3) Person having certificate of competency for electrical work issued by appropriate government /licenced electrical contractor shall always insurethat the wires from respective circuit are capable of withstanding intended load.
- 4) Identification of the incoming and outgoing supply circuit to be always displayed on every distribution box.
- 5) For protction purpose RCCB (Residual current circuit Breaker) of proper rating shall be installed in every circuit and kept operational.
- 6) Refilled fire extinguisher's shall always be kept near the electrical panel/ board.
- 7) All the electronics/medical equipments/air conditioners installed which are operational 24 x 7 hrscontinuously shall be always operated under the supervisin of operator of that field. also the maintainance of the equipments shall be done periodically.
- 8) Diesel generators shall be kept operational ,if installed along with necessary charging permissions & safety procedures.
- 9) All the electrical equipments shall be earthed efficiently. Records of The (Earth -Pit Wise) Earth Resistances Shall Be Maintained Periodically.
- 10) This certification is considerd invalid /cancelled for any addition /alteration made in the Electrical Load /System After The Inspection Of This Office .
- 11) This permission is vali for the period of 12 months from the date of issue.



Quauat
विद्युत निरीक्षक
विद्युत निरीक्षण विभाग
अमरावती