



महाराष्ट्र शासन

सत्यमेव जयते

विद्युत निरीक्षकांचे कार्यालय,  
राम-लक्ष्मण संकुल, ब्लॉक डी, 'शिवनेरी सदर पहीला माळा'  
कॉटन मार्केट रोड, विलास नगर, अमरावती

ईमेल : ciamaravati.nrg-mh@gov.in

दुरध्वनी क्र.०७२१ - २५७३७८६

जा.क्र./वि.नि./निरीक्षण/ ६०० /२०२४

दिनांक :- १८.०६.२०२४

To,

The Principle

School of scholars,

At- Nimbhora Khurd Near Sipna College, Badnera Road Amravati

Tq. Dist- Amravati

संदर्भ:- १. आपले निरीक्षण मागणी पत्र क्र- ५६ दिनांक- २७/५/२०२४.

२.या कार्यालयाचे निरीक्षण दिनांक ०३.०६.२०२४.

३.या कार्यालयाचे त्रुटी पत्र क्र.४००/०३.०६.२०२४ .

४. आपल्या संचमांडणीचा मे.अश्विन इलेक्ट्रिकल नागपुर यांनी प्रमाणितकेलेलाचाचणी अहवाल व त्रुटी पुर्तता क्र.१५२८/दिनांक २८.०५.२०२४.

उपरोक्त पत्रान्वये आपण विनंती केल्यानुसार प्राचार्य स्कूल ऑफ स्कॉलर्स, निभोरा खुर्द, सिपना कॉलेज जवळ अमरावती येथिल विद्युत संचमांडणीचे निरीक्षण या कार्यालयामार्फत दिनांक ०३.०६.२०२४ रोजी करण्यात आले असुन, सदर विद्युत संचमांडणी, विज कायदा २००३ व केंद्रीय विद्युत प्राधिकरण विनियम २०२३ च्या नियमानुसार खालील अटीच्या अधिन राहून सद्यस्थितीत सर्व साधारणपणे सुरक्षित असल्याबाबत प्रमाणित करण्यात येत आहे.

- 1) A person having certificate of competency for electrical work issued by appropriate government shall be appointed by user department for maintenance of electrical installation, addition/alteration of load /wiring.
- 2) wiring diagrams/singal line diagrams of all electrical installations along with load details shall be displayed at electrical panel room.
- 3) Person having certificate of competency for electrical work issued by appropriate government /licenced electrical contractor shall always insure that the wires from respective circuit are capable of withstanding intended load.
- 4) Identification of the incoming and outgoing supply circuit to be always displayed on every distribution box.
- 5) For protction purpose RCCB (Residual current circuit Breaker) of proper rating shall be installed in every circuit and kept operational.
- 6) Refilled fire extinguisher's shall always be kept near the electrical panel/ board.
- 7) All the electronics/medical equipments/air conditioners installed which are operational 24 x 7 hrs continuously shall be always operated under the supervisin of operator of that field. also the maintainance of the equipments shall be done periodically.
- 8) Diesel generators shall be kept operational ,if installed along with necessary charging permissions & safety procedures.
- 9) All the electrical equipments shall be earthed efficiently. Records of The (Earth -Pit Wise) Earth Resistances Shall Be Maintained Periodically.
- 10) This certification is considered invalid /cancelled for any addition /alteration made in the Electrical Load /System After The Inspection Of This Office .
- 11) This permission is vali for the period of 12 months from the date of issue.



*Quauat*  
विद्युत निरीक्षक  
विद्युत निरीक्षण विभाग  
अमरावती